

# BRIDGEWATER WATER DEPARTMENT

## ANNUAL WATER QUALITY REPORT

(JANUARY 2025 – DECEMBER 2025)

PWS ID Number: 4042000

The Bridgewater Water Department is committed to providing our customers with water that meets or exceeds all drinking water standards. To ensure that we continue to deliver this quality product, the Water Department has made significant investments over the years in new well sites, water quality monitoring, water source protection, water mains and water treatment.

We are extremely pleased to present our water quality report covering testing performed in 2025. This is indicative of our ability to consistently provide high quality water to our customers year after year. As regulations and drinking water standards change, our commitment to you will be to make appropriate changes in an economical manner. We will remain vigilant in meeting the challenges of source water protection, water conservation and community education while continuing to serve the needs of our water users. The Safe Drinking Water Act (SDWA) passed by Congress in 1974 requires water suppliers to report annually to their customers on the quality of their drinking water. This Annual “**Water Quality Report**” is designed to provide you with information you need to make educated decisions for yourself, your family, and your town.

This Report will be made available to you annually by July 1<sup>st</sup>. Included are details about your water source, what we are doing to protect it, what it contains, how it is treated and how it compares to standards set by regulatory agencies. Informed consumers are our best allies in maintaining safe drinking water. Please take the time to review this report and save it as a reference.

### Where Does Your Water Come From?

Our water supply comes from groundwater sources from 9 wells installed in three different aquifers in the Taunton River Basin. The first aquifer consists of four wells located on High Street near the Matfield River (Wells #3, #6, #8, and #9/#9R, MassDEP Source ID 4042000-02G, -05G, -09G, and -10G/-16G, respectively). The second aquifer supports five wells located in the vicinity of Carver’s Pond (active wells include Wells #2, #4a, and 5a/#5R, MassDEP Source ID 4042000-04G, -14G, and -13G/-15G, respectively). The third aquifer includes two wells located on Plymouth Street (Wells #10A and #10B, MassDEP Source ID 4042000-11G and -12G, respectively). The wells range in depth from 40-60 feet and are constructed in the sand and gravel deposits that overlie bedrock. The water is delivered to customers through approximately 130 miles of water mains ranging in size from 2 inches to 16 inches. The service pipe into your house is connected into the water main in the street.

The new High Street Water Treatment Plant (WTP) treats Wells 3, 6, 8, and 9/9R while the Carvers Pond WTP treats Wells 2, 4a, 5a/5R. The instrumentation and controls at the Carver Pond WTP were upgraded in May 2021. The High Street WTP is newly constructed and went online in February 2023. Both WTPs serve to remove iron and manganese from the source water, and also provide pH adjustment and disinfection. Sodium hydroxide is added to all the wells to reduce the groundwater’s natural acidity, to optimize disinfection effectiveness, and minimize the deterioration of household plumbing. Chlorine is added as a precaution against any bacteria that may be present. We carefully monitor the amount of chlorine in our water, only adding the minimum amount necessary to protect the safety of our water. The High Street WTP uses UV light in addition to chlorine for disinfection. UV light is not a requirement by MassDEP but provides additional protection against microbial contaminants.

The Water Department owns over 50 acres at Carver’s Pond and over 18 acres at High Street to protect our water sources. In addition, the Water Department has about 20 acres on Plymouth Street. The Water Department maintains two storage tanks with a total capacity of 4.7 million gallons. This storage capacity helps maintain system-wide pressure while at the same time providing water to meet times of high water usage and fire-fighting events.

### What Other Sources of Information Are Available?

MassDEP website:

[www.mass.gov/dep](http://www.mass.gov/dep);

CCR Information:

<https://www.epa.gov/ccr/ccr-information-consumers>

National Primary Drinking Water Regulations:

<https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulations>

U. S. Environmental

Protection Agency website:

<https://www.epa.gov/ground-water-and-drinking-water> ;

EPA Drinking Water Email:

[safewater@epa.gov](mailto:safewater@epa.gov)

### 2025 H<sub>2</sub>O Facts

**Total Water Pumped:  
564 Million Gallons**

**Average Per Capita  
Usage:  
54 Gallons/Day**

### Important Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by emailing the EPA at [safewater@epa.gov](mailto:safewater@epa.gov).

In order to ensure that tap water is safe to drink, EPA and MassDEP prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. FDA and Massachusetts Department of Public Health regulations establish limits for contaminants in bottled water that must provide the same protection for public health).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available by emailing the EPA at [safewater@epa.gov](mailto:safewater@epa.gov).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Bridgewater is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact *Bridgewater Water Department* at (508-697-0910). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

### Explanation of Expected Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, brooks, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up contaminants resulting from the presence of animals or human activity.

Contaminants that **may** be present in **untreated** source water include:

- *Microbial contaminants*, such as viruses and bacteria that may come from septic systems, wastewater treatment plants, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil or gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and

residential uses.

- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally occurring or the result of oil and gas production and mining activities.



### Water Quality Testing Results

Even though we tested for over **100** of the contaminants mentioned above, the included Water Quality Data Table shows only the substances that **were detected** in our treated drinking water. The presence of these contaminants in the water does not necessarily indicate that the water presents a health hazard. All other contaminants that we tested for were not detected. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent testing results are included along with the year in which the sample was taken. Except for PFAS6, all regulated contaminants were detected at levels well below the highest levels allowed in drinking water, which is shown in the Maximum Contaminant Level (MCL) column.

### Total Coliforms (including fecal coliform and E.Coli)

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify any problems that were found during these assessments. During the past year, we were required to conduct one Level 1 assessment. One Level 1 assessment was completed. In addition, we were required to take one corrective action and we completed this action. A Level 1 Assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system. Refer to note 3 on page 3 within the regulated contaminants table for details on coliform violation, as well as the attached drinking water notice.

## Water Quality Data Tables of Detected Regulated Contaminants

Contaminant	Date Collected	90 <sup>th</sup> Percentile <sup>1</sup>	Action Level	MCLG	# of Sites Tested <sup>2</sup>	# Sites Above Action Level	Range	Possible Source(s) of Contamination
Lead (ppb)	2025	3.2	15	0	59	0	ND – 12	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)		0.67	1.3	1.3	59	0	0.09 – 1.21	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

<sup>1</sup> Refer to the definition section on page 5 for an explanation of the 90<sup>th</sup> Percentile.

<sup>2</sup> Lead and Copper samples are collected by community volunteers. We were required to collect 60 samples annually in 2025, a notice was issued for failure to meet the requirement during the July 1 to December 31 monitoring period because only 59 samples were collected. We depend on residents to collect samples and we ask those residents who volunteer to collect samples to do so in a timely manner so we can avoid further violations. Refer to the attached notice of noncompliance. Town of Bridgewater has prepared a lead service line inventory and can be accessed from this link:

<https://apexmapping.maps.arcgis.com/apps/insant/sidebar/index.html?appid=b2fdcb026744981b7e54295d1e0f83c>

Regulated Contaminant	Date(s) Collected	Highest Result or Average Detected	Range Detected	MCL or MRDL	MCLG or MRDLG	Violation (Y/N)	Possible Source(s) of Contamination
<b>Inorganic Contaminants</b>							
Fluoride <sup>4</sup> (ppm)	July 2025	ND	ND	4 (SMCL=2)	4	N	Erosion of natural deposits; discharge from fertilizer and aluminum factories
Nitrate (ppm)	April 2025	2.28	1.42 – 2.28	10	10	N	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Tetrachloroethylene (ppb)	Jan 2025	0.60	ND – 0.60	5	0	N	Discharge from factories and dry cleaners; asbestos cement lined pipes
Perchlorate (ppb)	May, Sep 2025	0.13	0.05 – 0.13	2	NA	N	Rocket propellants, fireworks, munitions, flares, blasting agents
Barium (ppm)	July 2025	ND	ND	2	2	N	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits
PFAS <sup>6</sup> (ppt)	Monthly in 2025	25.47 <sup>6</sup>	8.29 – 29.80	20	NA	Y	Discharge and emission from industrial and manufacturing sources associated with PFAS, such as moisture and oil resistant coatings, and fire-fighting foam; use and disposal of products containing PFAS
<b>Radioactive Contaminants</b>							
Gross Alpha (pCi/L)	2025	ND	ND	15	0	N	Erosion of natural deposits
Radium 226 & 228 combined (pCi/L)	2025	0.63	ND-0.63	5	0	N	Erosion of natural deposits
<b>Disinfectants and Disinfection By-Products</b>							
Free Chlorine (ppm)	25 times per month, 2025	0.57 <sup>7</sup>	0.35 – 0.57	4 (MRDL)	4 (MRDLG)	N	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	Quarterly in 2025	20 <sup>7</sup>	8.8 – 32.3	60	NA	N	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHMs) (ppb)	Quarterly in 2025	56 <sup>7</sup>	20 – 66	80	NA	N	Byproduct of drinking water chlorination

<sup>3</sup> In September 2025, one water sample tested positive for coliform bacteria. We completed one Level 1 Assessment and implemented one corrective action by flushing the failed sampling points. Repeat samples were collected at the same sampling point later in September 2025, and all results were negative for coliform.

<sup>4</sup> Fluoride also has a secondary contaminant level (SMCL) of 2 ppm. Bridgewater does not add fluoride to the water system. The Massachusetts Department of Public Health strongly supports community Fluoridation as a safe, cost effective, and proven practice that promotes good oral health within our communities. The ideal fluoride concentration in drinking water to help prevent tooth decay and support dental health is a concentration of 0.7 parts per million (ppm) consistently. The optimal average monthly fluoridation concentration range is 0.6 – 0.8 ppm.

<sup>5</sup> Some people who drink water containing these PFAS in excess of the MCL

may experience certain adverse effects. These could include effects on the liver, blood, immune system, thyroid, and fetal development. These PFAS may also elevate the risk of certain cancers. For additional information on PFAS6, refer to the Attached notices of noncompliance, also available at:

<https://www.bridgewaterma.gov/Documents/Services/Public%20Works/Public%20Notices/> and <https://www.bridgewaterma.gov/Documents/Services/Public%20Works/Public%20Notices/> and <https://www.bridgewaterma.gov/Documents/Services/Public%20Works/Water%20Division/PFAS/>

<sup>6</sup> Highest quarterly locational average is reported.

<sup>7</sup> Highest quarterly locational running annual average is reported.

## Water Quality Data Tables of Detected Unregulated and Secondary Contaminants

Unregulated contaminants are those for which there are no established drinking water standards. The purpose of unregulated contaminant monitoring is to assist regulatory agencies in determining their occurrence in drinking water and whether future regulation is warranted.

Unregulated and Secondary Contaminants	Date(s) Collected	Average Detected	Range Detected	SMCL	ORSG	Possible Source(s) of Contamination
<b>Unregulated Contaminants</b>						
Acetone (ppm)	Jan., May, July, Oct. 2025	0.005	ND – 0.005	NA	6.3	Discharge from industrial production and use, in automobile exhaust, from landfills and natural sources
Alkalinity (mg/L as CaCO <sub>3</sub> )	Feb. 2023	54	54	NA	NA	Naturally occurring; result of water treatment process
Bromodichloromethane (ppb)	Quarterly in 2025	5.51	ND – 9.40	NA	NA	Byproduct of drinking water chlorination
Calcium (ppm)	Feb. 2023	14.7	14.7	NA	NA	Naturally occurring as groundwater percolates through minerals containing calcium
Chloroform (ppb)	Quarterly in 2025	5.65	ND – 9.7	NA	70	Byproduct of drinking water chlorination. In non-chlorinated sources, chloroform may be naturally occurring.
Dibromochloromethane (ppb)	Quarterly in 2025	2.83	ND – 4.5	NA	NA	Byproduct of drinking water chlorination
Hardness (mg/L as CaCO <sub>3</sub> )	Feb. 2023	80.5	80.5	NA	NA	Naturally occurring as groundwater percolates through minerals containing calcium or magnesium
Magnesium (ppm)	Feb. 2023	5.77	5.77	NA	NA	Naturally occurring as groundwater percolates through minerals containing magnesium
Sodium <sup>1</sup> (ppm)	July 2025	77.6	57 – 98.2	NA	20	Discharge from the use and improper storage of sodium-containing de-icing compounds or in water-softening agents
Potassium (ppm)	May 2021	4.71	4.71	NA	NA	Naturally occurring; runoff from fertilizer use
<b>Secondary Contaminants</b>						
Aluminum (ppb)	Feb 2023	ND	ND	200	NA	Residue from water treatment process; erosion of natural deposits
Chloride (ppm)	Feb 2023	116	116	250	NA	Runoff and leaching from natural deposits; seawater influence
Iron (ppb) <sup>2</sup>	2025	936	54 – 4820	300	NA	Naturally occurring, corrosion of cast iron pipes
Manganese <sup>3</sup> (ppb)	2025	270	9 – 667 <sup>4</sup>	50	300 <sup>5</sup>	Natural sources as well as discharges from industrial uses
Odor <sup>6</sup> (TON)	Feb 2023	8	8	3	NA	Erosion of natural deposits; leaching from wood preservatives
pH	Feb 2023	7.3	7.3	6.5 – 8.5	NA	Runoff and leaching from natural deposits
Sulfate (ppm)	Feb 2023	19.3	19.3	250	NA	Runoff and leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	Feb 2023	257	257	500	NA	Erosion of natural deposits
Zinc (ppm)	Feb 2023	0.005	0.005	5	NA	Naturally occurring; human activities such as melting metals, steel production, burning coal and certain wastes; zinc-coated metal pipes

1 Some people who drink water containing sodium at high concentrations for many years could experience an increase in blood pressure.

2 Use of water containing iron at concentrations above the secondary MCL may result in aesthetic issues including the staining of laundry and plumbing fixtures and water with an unpleasant metallic taste and rusty odor. Water samples collected at Well 10B show confirmed iron levels in excess of the SMCL. Iron was not monitored at Well 10 in August and December because the well was offline, and it was not monitored in April because monitoring was not required until our sampling schedule was updated in May. Additionally, Well 10B was off-line during November and December and alternative drinking water has been made available free of charge to the consumers from the self-service vending unit located at 151 High Street.

3 Drinking water may naturally have manganese and, when concentrations are greater than 50 ppb, the water may be discolored and taste bad. Over a lifetime, the EPA recommends that people drink water with manganese levels less than 300 ppb, and over the short term, EPA recommends that people limit their consumption of water with levels over 1000 ppb, primarily due to concerns about possible neurological effects. Children younger than one year old should not be given water with manganese concentration over 300

ppb, nor should formula for infants be made with that water for more than a total of ten days throughout the year.

4 Water samples collected at well 10B on 4/11/2025, 9/11/2025, and 10/20/2025 show confirmed manganese levels in excess of the Massachusetts Department of Environmental Protection (MassDEP) advisory level. Well 10B was off-line during November and December and was not providing drinking water to the distribution system, so no sampling was conducted. Alternative drinking water has been made available free of charge, 24/7, from the self-service vending unit located at 151 High Street. We have hired an engineering firm to work on a long-term solution to correct the quality of water that this well provides. Refer to the attached notices of noncompliance. Additionally, we missed manganese monitoring at system sites in July and August.

5 US EPA and MassDEP have established public health advisory (HA) levels for manganese to protect against concerns of potential neurological effects and a one-day and 10-day HA of 1000 ppb for acute exposure.

6 May produce a "rotten egg", musty, or chemical smell.

**Water Quality Table of Unregulated PFAS Contaminants**

PFAS6 is a group of 6 different contaminants that are regulated as a group. Other PFAS chemicals are unregulated. Two of the 12 unregulated PFAS contaminants were detected.

Unregulated PFAS Contaminants	Date(s) Collected	Average Detected	Range Detected
Perfluorobutane sulfonic acid (PFBS) (ppt)	Monthly in 2025	6.72 <sup>1</sup>	1.8 – 11.3
Perfluorohexanoic acid (PFHxA) (ppt)	Monthly in 2025	9.08 <sup>1</sup>	2.24 – 12.00

*1 Highest quarterly locational average is reported.*

**Abbreviations:**

- 90<sup>th</sup> Percentile** Lead and copper compliance is based on the 90<sup>th</sup> percentile value; out of every 10 homes sampled, 9 were at or below this level. This number is compared to the action level to determine lead and copper compliance. When the 90<sup>th</sup> percentile value is above the action level (AL), a public water system must implement corrosion control treatment. See the education statement on lead in water quality report on page 2 for more information.
- AL** Action Level. The concentration of contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- HAA** Haloacetic Acids.
- MCL** Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- MCLG** Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MRDL** Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

- MRDLG** Maximum Residual Disinfectant Level Goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- NA** Not Applicable.
- ND** Not Detected.
- ORSG** Office of Research and Standards Guideline.
- pCi/L** Picocuries per liter. A unit of radiation.
- PFAS** Per-and Polyfluoroalkyl Substance.
- ppb** Parts per billion or micrograms per liter (µg/L). This corresponds to 1 penny in \$10,000,000.
- ppm** Parts per million or milligrams per liter (mg/L). This corresponds to 1 penny in \$10,000.
- ppt** Parts per trillion or nanograms per liter (ng/L). This corresponds to 1 penny in \$10,000,000,000.
- SMCL** Secondary Maximum Contaminant Level. These are standards to protect the aesthetic quality of drinking water and are not health based.
- TON** Threshold Odor Number.
- TTHM** Total Trihalomethanes.
- HA** Health Advisory

**Cross-Connection Control and You**

Cross-connections that contaminate drinking water distribution lines are a major concern to us. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems), or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (back pressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand), causing contaminants to be sucked out from the equipment and into the drinking water line (back siphonage). Outside water taps and garden hoses tend to be the most common source of cross-connection contaminations at home. The garden hose creates a hazard when submerged in a swimming pool or when attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools, or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed, and maintained. We have surveyed industrial, commercial, and institutional facilities in the service area to make sure that potential cross-connections are identified and eliminated or protected by a backflow preventer.

We also inspect and test backflow preventers to make sure that they provide maximum protection. For more information on backflow prevention, contact the EPA at by emailing the EPA at [safewater@epa.gov](mailto:safewater@epa.gov).

**Regulatory Violations**

Our system failed to submit the 2023 Consumer Confidence Report (CCR) to MassDEP by July 1, 2024, deadline. Consequently, MassDEP issued a Notice of Noncompliance (NON) to Bridgewater Water Department (Department). Furthermore, the 2024 CCR failed to include the required explanation regarding this initial reporting violation. We have since updated our internal tracking to ensure all future annual reports are submitted and finalized on time. In addition, MassDEP issued the Department a Notice of Noncompliance in August 2024 for monitoring omissions related to Manganese because The Department failed to monitor Manganese during the second quarter of 2024, and PFAS because Results for PFAS were not reported for the months of April and June 2024. MassDEP issued notices regarding administrative and operational protocols to the Department, including a Notice of Noncompliance (NON) on December 1, 2025 for Sanitary Survey requirements and corrective actions related to the Cross Connection Control Program, and a Unilateral Administrative Order (UAO) on December 5, 2025 authorizing the town to utilize an interconnection during a water supply emergency. MassDEP issued a NON on January 28, 2026 regarding lead and copper samples (see page 3, note 2).

## **SOURCE WATER PROTECTION**

The Massachusetts Department of Environmental Protection has completed a Source Water Assessment and Protection (SWAP) Report for our system. The SWAP report assesses the susceptibility of public water supplies to potential contamination by microbiological pathogens and chemicals. A susceptibility ranking of high was assigned to our system using information collected during the assessment by MassDEP. A source's susceptibility to contamination does not imply poor water quality. Among the SWAP Report recommendations are public education; partnering with local businesses to ensure proper storage, handling, and disposal of hazardous wastes; monitoring progress on any remedial action at known contamination sites; and developing a wellhead protection plan. Source protection is a key element in providing good quality water.

Protecting our precious water resources is everyone's responsibility. If you observe any activity that could contaminate our drinking water supply, please contact us immediately. The complete SWAP Report is available at the Water Department Office and at MassDEP's website:

<https://www.mass.gov/service-details/the-source-water-assessment-protection-swap-program>.

### **Water Conservation Tips**

Here is how you can do your part to conserve water at home:

1. Fix leaking faucets, pipes, toilets, etc.
2. Install water-saving devices.
3. Wash only full loads of laundry.
4. Do not use the toilet for trash disposal.
5. Take shorter showers. Do not let the water run while shaving, washing, or brushing teeth.
6. Run the dishwasher only when full.
7. Water the lawn as little as possible.
8. Choose plants that do not need much water.
9. Obey water bans or regulations.

Homeowners are reminded that only handheld hoses can be used for outside watering and that underground irrigation systems cannot be connected to the Town's water system.

### **What If I Have Questions About My Water?**

Please call the office at: [508-697-0910](tel:508-697-0910)

**Contact Person: William Young, Water Superintendent.**



Water Department  
90 Cottage Street  
Bridgewater, MA 02324



**Massachusetts Department of Environmental Protection**  
**Bureau of Resource Protection – Drinking Water Program**  
**Coliform Bacteria Level 1 Assessment**

RTCR-1

PWS ID#: 4042000 PWS Name: Bridgewater Water

City/Town: Bridgewater

System Type: COM  NTNC  TNC

Compliance Period: Month September Year 2025

Assessment Trigger Date: 9/4/2025

Date Assessment Completed: 9/29/2025

**NOTE:** Form to be completed based on data and documents available to the PWS and returned to MassDEP as soon as practical but no later than 30 days after the collection date of the sample that triggered the assessment

**Section A:** Review and evaluate all the listed elements typically found in a PWS. Check any potential causes of contamination identified or check "NA" if the section is not applicable to the PWS. **Each section requires a response.**

**1. GENERAL**

Issue identified: YES  NO

Have any of the following occurred prior to collecting bacteria samples?

- low/inadequate disinfectant residual
- signs of vandalism/forced entry†
- water quality parameters out of range
- system does not provide disinfection
- other: College back in Town changes direction of flow and low tower levels
- pressure loss/inadequate pressure (<20 psi)\*
- visible indicators of unsanitary conditions
- power loss

**2. OPERATIONAL CHANGES**

Issue identified: YES  NO

- source added/removed
- other:
- operation/maintenance activities
- power loss

**3. SAMPLING SITES**

Issue identified: YES  NO

- unclean or unsuitable sample tap
- unapproved/alternate site
- other:
- change in conditions at sample site
- POE/POU treatment identified
- hot water intrusion

**4. SAMPLING PROTOCOL**

Issue identified: YES  NO

- improper sample container
- aerator was not removed
- lab indicates possible error
- other:
- sampler error
- inadequate tap flushing
- change in sample collector
- auto sensing faucet/swivel-type faucet
- improper hold time/storage temperature

**5. TREATMENT PROCESS**

Issue identified: YES  NO  NA

- O & M procedures not followed
- turbidity measurements out of range
- treatment added or changed
- phosphate barrels Cl<sub>2</sub> less than 10 mg/L free chlorine residual (not applicable when the phosphate contains zinc)
- other: Well 10B online
- unprotected by-pass in treatment process\*
- filter or media contamination
- interruption in treatment/power loss
- inadequate disinfection
- change in flow rates
- recent installation/repair

**6. DISTRIBUTION SYSTEM**

Issue identified: YES  NO  NA

- low flow/dead end
- standing water/debris in valve vault
- low disinfection residuals
- known bio-film accumulation
- unprotected cross connection\*
- improper operation of gate valves
- other:
- main breaks
- leaks
- illegal use of hydrants
- improper surge control
- booster pump failure
- operation of isolation valves resulting in breakage
- flushing of fire hydrants or blow-offs
- improper operation of air-relief/air-vacuum valves
- installation of new mains or construction activity
- fire fighting event/flushing/sheared hydrant

**7. STORAGE TANKS**Issue identified: YES  NO  NA 

- |  |  |   |
|--|--|---|
| <input type="checkbox"/> recent work on tank   | <input type="checkbox"/> evidence of contamination from animals  |   |
| <input type="checkbox"/> low disinfectant residual   | <input type="checkbox"/> presence of dead animals/insects        |   |
| <input type="checkbox"/> lack of maintenance, cleaning, or inspection  | <input type="checkbox"/> unauthorized access/signs of vandalism† |   |
| <input type="checkbox"/> standing water/debris in control vault  | <input type="checkbox"/> hatch not sealed                        | <input type="checkbox"/> Tank(s) out of service                   |
| <input type="checkbox"/> incorrect operation of level control valves/altitude valves/related appurtenances                           |  | <input checked="" type="checkbox"/> water age/inadequate turnover |
| <input type="checkbox"/> tank design issues (overflow, vent, hatch, screen size, etc.)   |  | <input type="checkbox"/> unaddressed inspection findings          |
| <input type="checkbox"/> deterioration, rust, holes, or other breaches in vent, overflow pipe, access hatch, screens, ladders, etc.* |  |   |
| <input type="checkbox"/> other:  |  |   |

**8. SOURCES**Issue identified: YES  NO  NA 

- |   |  |   |
|---|--|---|
| <input type="checkbox"/> damaged pitless adaptor        | <input type="checkbox"/> well pit with standing water or evidence of flooding* |   |
| <input type="checkbox"/> flooding/run-off inundation*   | <input type="checkbox"/> improper development/poorly maintained spring box     |   |
| <input type="checkbox"/> missing/damaged grout seal     | <input type="checkbox"/> defective/damaged well cap/well seal*                 | <input type="checkbox"/> damaged well casing*     |
| <input type="checkbox"/> recent work on pump            | <input type="checkbox"/> damaged/unscreened vent*                              | <input type="checkbox"/> unapproved source*       |
| <input type="checkbox"/> ground slopes towards well     | <input type="checkbox"/> activities in Zone I and/or Zone II                   | <input type="checkbox"/> change in sources        |
| <input type="checkbox"/> recent heavy rainfall/snowmelt | <input type="checkbox"/> unprotected opening in pump/pump assembly             | <input type="checkbox"/> well cap not water tight |
| <input type="checkbox"/> other:                         |  |   |

\* Indicates Groundwater Rule Significant Deficiency

† 310 CMR 22.15(9)(b)1.d. requires the discovery of malicious intent or an act of vandalism be reported to MassDEP within two hours.

**Section B - Issue Description** Use this space to describe the event and provide additional information on potential causes of contamination identified during the assessment. Include corresponding dates with your findings (attach additional pages if needed). Include dates of sample collection, disinfection, flushing, photographs showing system components, etc. with your findings.

Check if PWS did not find any causes for the contamination.

There was a major change in flow due to the college and schools being back in session. Low tower levels and little turnover resulting in Well 10B being turned on also changing the direction of flow and higher iron due to no filtration.

**Section C - Corrective Action Taken or to be Taken** Use this space to describe corrective actions completed, a proposed timetable for any corrective actions not already completed, and any interim measures the PWS plans to implement prior to the completion of any corrective actions, including specific milestone dates for doing so (attach additional pages if needed). Include photographs showing system components. Failure to meet milestone dates is subject to enforcement and public notice provisions.

Flushed failed sampling points. May just be due to multiple flow changes, as both sites had ~.50 mg/L residual. While Well 10B may be a contributing, it can't be turned off until we have stable conditions in the towers. ~3-year project in the works to have 10B piped over to High St. to be filtered and treated there.

**Section D - Compliance History**

1. Was the PWS required to complete a Level 1 Assessment in the last 12 months? Yes  No   
If Yes, was the source of contamination identified? Yes  No
2. Was the PWS required by MassDEP during the last survey, inspection or other communication to address any issue(s)? Yes  No   
If yes, date issue was identified \_\_\_\_\_. Were all corrective actions completed? Yes  No   
If no, describe the issue and indicate your plan and a proposed timetable for any corrective actions. (attach additional pages if needed)

**NOTE:** The PWS is responsible for correcting all open violations. Contact your MassDEP Regional Office for assistance with violation and enforcement actions.

**Certification:** I certify under penalty of law that I am the person authorized to fill out this form, and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Print Name: Caleb Treacy-Schlough Title: Chief Operator  
Signature: *Caleb Treacy-Schlough* Date: 9/29/2025  
Phone #: 774-380-0124 Email: ctreacyschlough@bridgewaterma.org

Please return this form to your **MassDEP Drinking Water Program** regional office

**DWP USE ONLY:** MassDEP Reviewer: \_\_\_\_\_

Level 1 Assessment Accepted: YES  NO  PWS has corrected the problem: YES  NO

MassDEP Consultation Date if needed : \_\_\_\_\_

Corrective Action Plan approved: YES  NO  NA  Approved With Changes (attached)

Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## Bridgewater Water Department has levels of PFAS6 above the Drinking Water Standard

*This report contains important information about your drinking water.*

*Please translate it or speak with someone who understands it or ask the contact listed below for a translation.*

### ***What happened?***

**Our water system recently violated a drinking water standard** and we are taking the following corrective actions: We have contracted with an engineering firm to determine possible solutions including installing treatment to remove PFAS. In the interim, we have installed a self-service vending unit with PFAS removal treatment at 151 High Street, to provide residents drinking water with levels of PFAS6 below the drinking water standard. See information about filling station in the “What is being done?” section below.

### ***What does this mean?***

**This is not an emergency. If it had been, you would have been notified within 24 hours.** Although this is not an emergency, as our customer, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

On October 2, 2020, Massachusetts Department of Environmental Protection (MassDEP) promulgated a drinking water regulation and maximum contaminant level (MCL) of 20 nanograms per liter (ng/L) for the sum of six per- and polyfluoroalkyl substances (called PFAS6). An MCL exceedance or violation occurs when the average of all monthly samples collected during the calendar quarter exceeds the MCL. See our latest PFAS6 results for wells entering the distribution system over the MCL in the tables below.

<b>PFAS6 Results for Wells 10A and 10B</b>					
Quarterly Compliance Period	Monitoring Period	Sample Collection Date	PFAS6 Result (ng/L)	Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 2, 2025	Month 1	4/7/25	19.8	<b>21</b>	<b>20</b>
	Month 2	5/12/25	20.7		
	Month 3	6/2/25	22.1		

<b>PFAS6 Results for Carvers Pond Treatment Plant</b>					
Quarterly Compliance Period	Monitoring Period	Sample Collection Date	PFAS6 Result (ng/L)	Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 2, 2025	Month 1	4/7/25	22.5	<b>23</b>	<b>20</b>
	Month 2	5/12/25	21.3		
	Month 3	6/2/25	25.8		

Our results are above the MCL for PFAS6. Even though we have been notifying you of our results since we began collecting samples, to comply with the drinking water regulation, we must provide you with this public notice.

***Some people who drink water containing these PFAS in excess of the MCL may experience certain adverse effects. These could include effects on the liver, blood, immune system, thyroid, and fetal development. These PFAS may also elevate the risk of certain cancers.*** For more information on PFAS6 see the attached factsheet and weblinks listed below.

### ***What is PFAS6?***

PFAS6 includes perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorononanoic acid (PFNA), perfluorohexanesulfonic acid (PFHxS), perfluorodecanoic acid (PFDA) and perfluoroheptanoic acid (PFHpA). PFAS are

man-made chemicals that have been used in the manufacturing of certain fire-fighting foams, moisture and stain resistant products, and other industrial processes. For more information see the factsheet and weblinks listed below.

### ***What do I need to do?***

- **Consumers in a sensitive subgroup (pregnant or nursing women, infants and people diagnosed by their health care provider to have a compromised immune system), are advised not to consume, drink, or cook with water when the level of PFAS6 is above 20 ng/L.**
- **Consumers in sensitive subgroups** are advised to use bottled water for drinking and cooking of foods that absorb water (like pasta).
- **For infant formula**, use bottled water or use formula that does not require adding water.
- **For older children and adults not in a sensitive subgroup**, the 20 ng/L value is applicable to a lifetime of consuming the water. For these groups, shorter duration exposures present less risk. However, if you are concerned about your exposure while steps are being taken to assess and lower the PFAS concentration in the drinking water, use of bottled water<sup>1</sup> will reduce your exposure.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test for PFAS. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers->
- **Home water treatment systems** that are certified to remove PFAS by an independent testing group such as NSF, UL, or Water Quality Association may be used to treat the water. These may include point of entry systems, which treat all the water entering a home, or point of use devices, which treat water where it is used, such as at a faucet. For information on selecting home treatment devices that are effective in treating the water for PFAS6, review the MassDEP factsheet for consumers referenced below.
- **In most situations the water can be safely used for washing foods, brushing teeth, bathing, and showering.**
- **Boiling the water will not destroy PFAS6** and will somewhat increase its level due to evaporation of some of the water.
- **If you have specific health concerns regarding exposure, you should see the Centers for Disease Control's link below and consult a health professional, such as your doctor.**

For more information see the factsheet and weblinks listed below.

### ***What is being done?***

The Bridgewater Water Department has taken the following pro-active measures:

- The Bridgewater Water Department has installed a vending unit, located at 151 High Street, for residents to use free of charge. The vending unit has treatment that removes PFAS6 from the drinking water, recent results are non-detect for PFAS6 and Manganese. The vending unit is open for use 24/7 and residents are reminded to bring their own clean containers.
- We will continue to sample our water sources for PFAS to determine if it is possible to reliably blend sources below 20 ng/L.
- We are investigating treatment options for possible future use of Granular Activated Carbon (GAC).
- While we are working towards a long-term solution, we have made operational adjustments, blending, and mixing the sources with increased PFAS6 levels with other sources to possibly reduce the overall PFAS6 levels.
- We will provide updates and make information available on the town website:  
<https://www.bridgewaterma.org/1481/PFAS-Information-Results>

### ***Where can I get more information?***

If you have questions about your water system's operation, water quality monitoring, or response to this issue, please contact the system operator directly. If you have questions about the drinking water regulations or health risks posed by this contaminant you can contact the MassDEP Drinking Water Program at: [program.director-dwp@mass.gov](mailto:program.director-dwp@mass.gov) or (617) 292-5770. If you have questions about specific symptoms, you can contact your doctor or other health care provider. If you have general questions about public health, you can contact the Massachusetts Department of Public Health at 1-617-624-5757.

For more information, please contact Jonas Kazlauskas at 508-697-0910 or at [Jkazlauskas@bridgewaterma.org](mailto:Jkazlauskas@bridgewaterma.org)  
Bridgewater Water Department, 90 Cottage Street, Bridgewater, MA 02324.

- [\*\*MassDEP Fact Sheet - Questions and Answers for Consumers\*\*](https://www.mass.gov/media/1854351) (<https://www.mass.gov/media/1854351>)
- [\*\*CDC ATSDR Information on PFAS for consumers and health professionals\*\*](https://www.atsdr.cdc.gov/pfas/index.html)  
(<https://www.atsdr.cdc.gov/pfas/index.html>)
- [\*\*Massachusetts Department of Public Health information about PFAS in Drinking Water -\*\*](https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water)  
<https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water>

This notice is being sent to you by:

Bridgewater Water Department

System ID#: 4042000

Date distributed: 07/2/2025

We will continue to provide public notice updates as required until the situation has been resolved.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## Bridgewater Water Department has levels of PFAS6 above the Drinking Water Standard

*This report contains important information about your drinking water.*

*Please translate it or speak with someone who understands it or ask the contact listed below for a translation.*

### ***What happened?***

**Our water system recently violated a drinking water standard for per- and polyfluoroalkyl substances (PFAS) and we are taking the following corrective actions:** We have contracted with an engineering firm to determine possible solutions including installing treatment to remove PFAS. In the interim, we have installed a self-service vending unit with PFAS removal treatment at 151 High Street, to provide residents drinking water with levels of PFAS6 below the drinking water standard. See information about filling station in the “What is being done?” section below.

### ***What does this mean?***

**This is not an emergency. If it had been, you would have been notified within 24 hours.** Although this is not an emergency, as our customer, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

On October 2, 2020, Massachusetts Department of Environmental Protection (MassDEP) promulgated a drinking water regulation and maximum contaminant level (MCL) of 20 nanograms per liter (ng/L) for the sum of six per- and polyfluoroalkyl substances (called PFAS6). An MCL exceedance or violation occurs when the average of all monthly samples collected during the calendar quarter exceeds the MCL. See our latest PFAS6 results for wells entering the distribution system over the MCL in the table below.

<b>PFAS6 Results for Carvers Pond Treatment Plant</b>					
<b>Quarterly Compliance Period</b>	<b>Monitoring Period</b>	<b>Sample Collection Date</b>	<b>PFAS6 Result (ng/L)</b>	<b>Quarterly Average (ng/L)</b>	<b>PFAS6 MCL (ng/L)</b>
Quarter 3, 2025	Month 1	7/1/25	20.0	23	20
	Month 2	8/5/25	22.2		
	Month 3	9/8/25	26.0		

Our results are above the MCL for PFAS6. Even though we have been notifying you of our results since we began collecting samples, to comply with the drinking water regulation, we must provide you with this public notice.

***Some people who drink water containing these PFAS in excess of the MCL may experience certain adverse effects. These could include effects on the liver, blood, immune system, thyroid, and fetal development. These PFAS may also elevate the risk of certain cancers.*** For more information on PFAS6 see the attached factsheet and weblinks listed below.

### ***What is PFAS6?***

PFAS6 includes perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorononanoic acid (PFNA), perfluorohexanesulfonic acid (PFHxS), perfluorodecanoic acid (PFDA) and perfluoroheptanoic acid (PFHpA). PFAS are man-made chemicals that have been used in the manufacturing of certain fire-fighting foams, moisture and stain resistant products, and other industrial processes. For more information see the factsheet and weblinks listed below.

### ***What do I need to do?***

- **Consumers in a sensitive subgroup (pregnant or nursing women, infants and people diagnosed by their health care provider to have a compromised immune system), are advised not to consume, drink, or cook with water when the level of PFAS6 is above 20 ng/L.**
- **Consumers in sensitive subgroups** are advised to use bottled water for drinking and cooking of foods that absorb water (like pasta).
- **For infant formula,** use bottled water or use formula that does not require adding water.

- **For older children and adults not in a sensitive subgroup**, the 20 ng/L value is applicable to a lifetime of consuming the water. For these groups, shorter duration exposures present less risk. However, if you are concerned about your exposure while steps are being taken to assess and lower the PFAS concentration in the drinking water, use of bottled water<sup>1</sup> will reduce your exposure.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test for PFAS. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers->
- **Home water treatment systems** that are certified to remove PFAS by an independent testing group such as NSF, UL, or Water Quality Association may be used to treat the water. These may include point of entry systems, which treat all the water entering a home, or point of use devices, which treat water where it is used, such as at a faucet. For information on selecting home treatment devices that are effective in treating the water for PFAS6, review the MassDEP factsheet for consumers referenced below.
- **In most situations the water can be safely used for washing foods, brushing teeth, bathing, and showering.**
- **Boiling the water will not destroy PFAS6** and will somewhat increase its level due to evaporation of some of the water.
- **If you have specific health concerns regarding exposure, you should see the Centers for Disease Control's link below and consult a health professional, such as your doctor.**

For more information see the factsheet and weblinks listed below.

### *What is being done?*

The Bridgewater Water Department has taken the following pro-active measures:

- The Bridgewater Water Department has installed a vending unit, located at 151 High Street, for residents to use free of charge. The vending unit has treatment that removes PFAS6 from the drinking water, recent results are non-detect for PFAS6 and Manganese. The vending unit is open for use 24/7 and residents are reminded to bring their own clean containers.
- We will continue to sample our water sources for PFAS to determine if it is possible to reliably blend sources below 20 ng/L.
- We are investigating treatment options for possible future use of Granular Activated Carbon (GAC).
- While we are working towards a long-term solution, we have made operational adjustments, blending, and mixing the sources with increased PFAS6 levels with other sources to possibly reduce the overall PFAS6 levels.
- We will provide updates and make information available on the town website:  
<https://www.bridgewaterma.org/1481/PFAS-Information-Results>

### *Where can I get more information?*

If you have questions about your water system's operation, water quality monitoring, or response to this issue, please contact the system operator directly. If you have questions about the drinking water regulations or health risks posed by this contaminant you can contact the MassDEP Drinking Water Program at: [program.director-dwp@mass.gov](mailto:program.director-dwp@mass.gov) or (617) 292-5770. If you have questions about specific symptoms, you can contact your doctor or other health care provider. If you have general questions about public health, you can contact the Massachusetts Department of Public Health at 1-617-624-5757.

For more information, please contact the Water Department at 508-697-0910 or at [waterdepartment@bridgewaterma.org](mailto:waterdepartment@bridgewaterma.org) Bridgewater Water Department, 25 South Street, Bridgewater, MA 02324.

- [MassDEP Fact Sheet - Questions and Answers for Consumers \(https://www.mass.gov/media/1854351\)](https://www.mass.gov/media/1854351)
- [CDC ATSDR Information on PFAS for consumers and health professionals \(https://www.atsdr.cdc.gov/pfas/index.html\)](https://www.atsdr.cdc.gov/pfas/index.html)
- [Massachusetts Department of Public Health information about PFAS in Drinking Water - https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water](https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water)

This notice is being sent to you by:

Bridgewater Water Department

System ID#: 4042000

Date distributed: 10/15/2025

We will continue to provide public notice updates as required until the situation has been resolved.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

# IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

## Bridgewater Water Department has levels of PFAS6 above the Drinking Water Standard

*This report contains important information about your drinking water.*

*Please translate it or speak with someone who understands it or ask the contact listed below for a translation.*

### ***What happened?***

**Our water system recently violated a drinking water standard**, and we are taking the following corrective actions: We have contracted with an engineering firm to determine possible solutions including installing treatment to remove PFAS. In the interim, we have installed a self-service vending unit with PFAS removal treatment at 151 High Street, to provide residents drinking water with levels of PFAS6 below the drinking water standard. See information about filling station in the “What is being done?” section below.

### ***What does this mean?***

**This is not an emergency. If it had been, you would have been notified within 24 hours.** Although this is not an emergency, as our customer, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

On October 2, 2020, Massachusetts Department of Environmental Protection (MassDEP) promulgated a drinking water regulation and maximum contaminant level (MCL) of 20 nanograms per liter (ng/L) for the sum of six per- and polyfluoroalkyl substances (called PFAS6). An MCL exceedance or violation occurs when the average of all monthly samples collected during the calendar quarter exceeds the MCL. See our latest PFAS6 results for wells entering the distribution system over the MCL in the tables below.

PFAS6 Results for Carvers Pond Treatment Plant					
Quarterly Compliance Period	Monitoring Period	Sample Collection Date	PFAS6 Result (ng/L)	Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 4, 2025	Month 1	10/6/2025	29.8	21	20
	Month 2	11/24/25	16.8		
	Month 3	12/22/25	15.9		

PFAS6 Results for Well 10B					
Quarterly Compliance Period	Monitoring Period	Sample Collection Date	PFAS6 Result (ng/L)	Quarterly Average (ng/L)	PFAS6 MCL (ng/L)
Quarter 4, 2025	Month 1	10/6/2025	25.2	25	20
	Month 2	*			
	Month 3	*			
*Source was offline and not providing drinking water during the month					

Our results are above the MCL for PFAS6. Even though we have been notifying you of our results since we began collecting samples, to comply with the drinking water regulation, we must provide you with public notice.

***Some people who drink water containing these PFAS in excess of the MCL may experience certain adverse effects. These could include effects on the liver, blood, immune system, thyroid, and fetal development. These PFAS may also elevate the risk of certain cancers.*** For more information on PFAS6 see the attached factsheet and weblinks listed below.

## ***What is PFAS6?***

PFAS6 includes perfluorooctanoic acid (PFOA), perfluorooctane sulfonic acid (PFOS), perfluorononanoic acid (PFNA), perfluorohexanesulfonic acid (PFHxS), perfluorodecanoic acid (PFDA) and perfluoroheptanoic acid (PFHpA). PFAS are man-made chemicals that have been used in the manufacturing of certain fire-fighting foams, moisture and stain resistant products, and other industrial processes. For more information see the factsheet and weblinks listed below.

## ***What do I need to do?***

- **Consumers in a sensitive subgroup (pregnant or nursing women, infants and people diagnosed by their health care provider to have a compromised immune system), are advised not to consume, drink, or cook with water when the level of PFAS6 is above 20 ng/L.**
- **Consumers in sensitive subgroups** are advised to use bottled water for drinking and cooking of foods that absorb water (like pasta).
- **For infant formula**, use bottled water or use formula that does not require adding water.
- **For older children and adults not in a sensitive subgroup**, the 20 ng/L value is applicable to a lifetime of consuming the water. For these groups, shorter duration exposures present less risk. However, if you are concerned about your exposure while steps are being taken to assess and lower the PFAS concentration in the drinking water, use of bottled water<sup>1</sup> will reduce your exposure.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test for PFAS. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers->
- **Home water treatment systems** that are certified to remove PFAS by an independent testing group such as NSF, UL, or Water Quality Association may be used to treat the water. These may include point of entry systems, which treat all the water entering a home, or point of use devices, which treat water where it is used, such as at a faucet. For information on selecting home treatment devices that are effective in treating the water for PFAS6, review the MassDEP factsheet for consumers referenced below.
- **In most situations the water can be safely used for washing foods, brushing teeth, bathing, and showering.**
- **Boiling the water will not destroy PFAS6** and will somewhat increase its level due to evaporation of some of the water.
- **If you have specific health concerns regarding exposure, you should see the Centers for Disease Control's link below and consult a health professional, such as your doctor.**

For more information see the factsheet and weblinks listed below.

## ***What is being done?***

The Bridgewater Water Department has taken the following pro-active measures:

- The Bridgewater Water Department has installed a vending unit, located at 151 High Street, for residents to use free of charge. The vending unit has treatment that removes PFAS6 from the drinking water, recent results are non-detect for PFAS6 and Manganese. The vending unit is open for use 24/7 and residents are reminded to bring their own clean containers.
- We will continue to sample our water sources for PFAS to determine if it is possible to reliably blend sources below 20 ng/L.
- We are investigating treatment options for possible future use of Granular Activated Carbon (GAC).
- While we are working towards a long-term solution, we have made operational adjustments, blending, and mixing the sources with increased PFAS6 levels with other sources to possibly reduce the overall PFAS6 levels.
- We will provide updates and make information available on the town website:  
<https://www.bridgewaterma.org/1481/PFAS-Information-Results>

## ***Where can I get more information?***

If you have questions about your water system's operation, water quality monitoring, or response to this issue, please contact the system operator directly. If you have questions about the drinking water regulations or health risks posed by this contaminant you can contact the MassDEP Drinking Water Program at: [program.director-dwp@mass.gov](mailto:program.director-dwp@mass.gov) or (617) 292-5770. If you have questions about specific symptoms, you can contact your doctor or other health care provider. If you have general questions about public health, you can contact the Massachusetts Department of Public Health at 1-617-624-5757.

For more information, please contact the Bridgewater Water Department at 508-697-0910 or at [waterdepartment@bridgewaterma.org](mailto:waterdepartment@bridgewaterma.org) Bridgewater Water Department, 25 South Street, Bridgewater, MA 02324.

- [\*\*MassDEP Fact Sheet - Questions and Answers for Consumers\*\*](https://www.mass.gov/media/1854351) (<https://www.mass.gov/media/1854351>)
- [\*\*CDC ATSDR Information on PFAS for consumers and health professionals\*\*](https://www.atsdr.cdc.gov/pfas/index.html) (<https://www.atsdr.cdc.gov/pfas/index.html>)
- [\*\*Massachusetts Department of Public Health information about PFAS in Drinking Water -\*\*](https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water) <https://www.mass.gov/service-details/per-and-polyfluoroalkyl-substances-pfas-in-drinking-water>

This notice is being sent to you by:

Bridgewater Water Department

System ID#: 4042000

Date distributed: 1/20/2026

We will continue to provide public notice updates as required until the situation has been resolved.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*



## Bridgewater Water Department has Very Important Information about Manganese in Your Drinking Water

-- Translate it or speak with someone who understands it --

### What happened?

A water sample collected at well 10B on 4/11/25 shows confirmed manganese levels of 0.381 milligrams per liter (mg/L) which is in excess of the Massachusetts Department of Environmental Protection (MassDEP) advisory level of 0.3 mg/L. While manganese is necessary for proper nutrition, an excess could adversely affect health.

### What should I do?

- **Infant formula should be prepared with bottled water** or made with water from an alternate source with manganese levels below 0.3 mg/L.
- **Use bottled water for infants less than 1 year of age** or water from a source with a manganese level below 0.3 mg/L.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test their water. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers->
- **The general population may continue to use the water** since it is anticipated that this issue will be resolved before long-term exposures occur.
- **If you have health related concerns about manganese**, contact your health care provider.
- **For more information on manganese** see the MassDEP Manganese Consumer FAQ: <https://www.mass.gov/doc/manganese-in-drinking-water-typical-questions-and-answers-for-consumers-0/download>

### What does this mean?

Drinking water may naturally have manganese, which is necessary for proper nutrition, but an excess could adversely affect health. **MassDEP advises that people drink water with manganese levels less than 0.3 mg/L over a lifetime, and also advises that people limit their consumption of water with levels over 1 mg/L, primarily to decrease the possibility of adverse neurological effects. Infants up to 1 year of age should not be given water with manganese over 0.3 mg/L, nor should formula for infants be made with that water for more than a total of 10 days throughout the year.** *The general population water concentration exposure limits of 0.3 and 1 mg/L have been set based upon typical daily dietary manganese intake levels not known to be associated with adverse health effects. This does not imply that intakes above these levels will necessarily cause health problems. Individual requirements for, as well as adverse effects from manganese can be highly variable.*

### What is being done?

- Well 10B is one of three locations that provide drinking water to the distribution system. Results from the 2 other locations, High Street and Cavers Pond were Non-Detect for Manganese. Out of an abundance of caution we will be collecting additional distribution samples that are representative of the area that receives drinking water from Well 10B, last year The results ranged from 0.056 to 0.116 which are below the health advisory. Distribution sample results are expected to be lower because the water from well 10B is blending with water from other sources within the distribution system.
- In addition, for Bridgewater residents who would still prefer alternative water we have made drinking water available free of charge, 24/7, from the self-service vending unit located at 151 High Street. The vending unit has treatment that removes contaminants from the drinking water, including manganese and Per- and poly-fluorinated (PFAS) compounds. Residents are reminded they need to bring their own clean bottles
- We have hired an engineering firm, to work on a long-term solution to correct the quality of water that this well provides.
- We will continue to monitor for manganese, work to lower the manganese concentrations and work with the MassDEP to keep you informed of all current information on this issue.

If you have questions for our Water Department, contact Water Dept. at 508-697-0910 or [watersewer@bridgewaterma.org](mailto:watersewer@bridgewaterma.org) or mail us at 25 South St Bridgewater Ma. 02324

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).*



## Bridgewater Water Department has Very Important Information about Manganese in Your Drinking Water

-- Translate it or speak with someone who understands it --

### What happened?

A water sample collected at well 10B on 9/11/25 shows confirmed manganese levels of 0.448 milligrams per liter (mg/L) which is in excess of the Massachusetts Department of Environmental Protection (MassDEP) advisory level of 0.3 mg/L. While manganese is necessary for proper nutrition, an excess could adversely affect health.

### What should I do?

- **Infant formula should be prepared with bottled water** or made with water from an alternate source with manganese levels below 0.3 mg/L.
- **Use bottled water for infants less than 1 year of age** or water from a source with a manganese level below 0.3 mg/L.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test their water. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers->
- **The general population may continue to use the water** since it is anticipated that this issue will be resolved before long-term exposures occur.
- **If you have health related concerns about manganese**, contact your health care provider.
- **For more information on manganese** see the MassDEP Manganese Consumer FAQ: <https://www.mass.gov/doc/manganese-in-drinking-water-typical-questions-and-answers-for-consumers-0/download>

### What does this mean?


Drinking water may naturally have manganese, which is necessary for proper nutrition, but an excess could adversely affect health. **MassDEP advises that people drink water with manganese levels less than 0.3 mg/L over a lifetime, and also advises that people limit their consumption of water with levels over 1 mg/L, primarily to decrease the possibility of adverse neurological effects. Infants up to 1 year of age should not be given water with manganese over 0.3 mg/L, nor should formula for infants be made with that water for more than a total of 10 days throughout the year.** *The general population water concentration exposure limits of 0.3 and 1 mg/L have been set based upon typical daily dietary manganese intake levels not known to be associated with adverse health effects. This does not imply that intakes above these levels will necessarily cause health problems. Individual requirements for, as well as adverse effects from manganese can be highly variable.*

### What is being done?

- Out of an abundance of caution we collected additional distribution samples that are representative of the area that receives drinking water from Well 10B, on 9/15/25. The results ranged from 0 to 0.102 which are below the health advisory. Well 10B is one of three locations that provide drinking water to the distribution system. Results from the 2 other locations, High Street and Cavers Pond, were Non-Detect for Manganese. Distribution sample results are expected to be lower because the water from well 10B is blending with water from other sources within the distribution system.
- In addition, for Bridgewater residents who would still prefer alternative water we have made drinking water available free of charge, 24/7, from the self-service vending unit located at 151 High Street. The vending unit has treatment that removes contaminants from the drinking water, including manganese and Per- and poly-fluorinated (PFAS) compounds. Residents are reminded they need to bring their own clean bottles
- We have hired an engineering firm to work on a long-term solution to correct the quality of water that this well provides.
- We will continue to monitor for manganese, work to lower the manganese concentrations and work with the MassDEP to keep you informed of all current information on this issue.

If you have questions for our Water Department, contact at 508-697-0910, email: [watersewer@bridgewaterma.org](mailto:watersewer@bridgewaterma.org) mail at 25 South St Bridgewater MA. 02324. visit website: <https://www.bridgewaterma.org/177/Water-Supply-Water-Dept>

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).*



## Bridgewater Water Department has Very Important Information about Manganese in Your Drinking Water

-- Translate it or speak with someone who understands it --

### What happened?

A water sample collected at Well 10B on 10/20/2025 shows a confirmed manganese level of 0.471 milligrams per liter (mg/L) which is in excess of the Massachusetts Department of Environmental Protection (MassDEP) advisory level of 0.3 mg/L. Additionally, a distribution system sample collected that same day on Plymouth Street had a manganese level of 0.610 mg/L. While manganese is necessary for proper nutrition, an excess could adversely affect health. Well 10B was off line during November and December and was not providing drinking water to the distribution system.

### What should I do?

- **Infant formula should be prepared with bottled water** or made with water from an alternate source with manganese levels below 0.3 mg/L.
- **Use bottled water for infants less than 1 year of age** or water from a source with a manganese level below 0.3 mg/L.
- **Bottled water should only be used if it has been tested.** The Massachusetts Department of Public Health requires companies licensed to sell or distribute bottled water or carbonated non-alcoholic beverages to test their water. See <https://www.mass.gov/info-details/water-quality-standards-for-bottled-water-in-massachusetts#list-of-bottlers>
- **The general population may continue to use the water** since it is anticipated that this issue will be resolved before long-term exposures occur.
- **If you have health related concerns about manganese**, contact your health care provider.
- **For more information on manganese** see the MassDEP Manganese Consumer FAQ: <https://www.mass.gov/doc/manganese-in-drinking-water-typical-questions-and-answers-for-consumers-0/download>

### What does this mean?

Drinking water may naturally have manganese, which is necessary for proper nutrition, but an excess could adversely affect health. **MassDEP advises that people drink water with manganese levels less than 0.3 mg/L over a lifetime, and also advises that people limit their consumption of water with levels over 1 mg/L, primarily to decrease the possibility of adverse neurological effects. Infants up to 1 year of age should not be given water with manganese over 0.3 mg/L, nor should formula for infants be made with that water for more than a total of 10 days throughout the year.**

*The general population water concentration exposure limits of 0.3 and 1 mg/L have been set based upon typical daily dietary manganese intake levels not known to be associated with adverse health effects. This does not imply that intakes above these levels will necessarily cause health problems. Individual requirements for, as well as adverse effects from manganese can be highly variable.*

### What is being done?

- Alternative drinking water has been made available free of charge, 24/7, from the self-service vending unit located at 151 High Street. The vending unit has treatment that removes contaminants from the drinking water, including manganese and Per- and poly-fluorinated (PFAS) compounds. Residents are reminded they need to bring their own clean bottles
- We have hired an engineering firm to work on a long-term solution to correct the quality of water that this well provides.
- We will continue to monitor for manganese, work to lower the manganese concentrations and work with the MassDEP to keep you informed of all current information on this issue.

If you have questions for our Water Department, contact Water Dept. at 508-697-0910 or [watersewer@bridgewaterma.org](mailto:watersewer@bridgewaterma.org) or mail us at 25 South St Bridgewater MA 02324.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses).*

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER**  
**Monitoring Requirements Not Met for Bridgewater**

Our water system violated a drinking water standard in 2025. Even though this is not an emergency, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. **During the July 1<sup>st</sup> to December 31<sup>st</sup>, 2025, monitoring period, we did not obtain the minimum number of required samples for lead and copper.**

**What should I do?**

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample, how many samples we were supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

<b>Contaminant</b>	<b>Required sampling frequency</b>	<b>Number of samples taken</b>	<b>When all samples should have been taken</b>	<b>When samples were or will be taken</b>
Lead and Copper	60 Samples Semiannually	59	59 out of 60 Samples were obtained 7/1/2025 – 12/31/2025	1/1/2026 to 6/30/2026

**What happened? What is being done?**

The Bridgewater Water Department miscounted the number of samples taken due to an address being counted twice.

For more information, please contact Bridgewater Water Department office at (508) 697-0910 or [waterdepartment@bridgewaterma.org](mailto:waterdepartment@bridgewaterma.org)

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the 2025 CCR

PWS ID#: **4042000**

Date distributed: 4/2/26