

Bridgewater Water Supply			PFAS
PFAS6 Results for Wells #1, 2, 4A and 5A			
Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	11.2	20
Quarter 2	April - June	21.5	20
Quarter 3	July - September	19.8	20
Quarter 4	October - December	18.1	20
PFAS6 Results for High Street Wells # 3 and # 6			
Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	10.1	20
Quarter 2	April - June	9.3	20
Quarter 3	July - September	11.0	20
Quarter 4	October - December	12.5	20
PFAS6 Results for High Street Wells # 8 and # 9			
Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	11.5	20
Quarter 2	April - June	12.4	20
Quarter 3	July - September	13.7	20
Quarter 4	October - December	offline	20
PFAS6 Results for Plymouth Street Wells # 10A and # 10B			
Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	14.8	20
Quarter 2	April - June	14.6	20
Quarter 3	July - September	14.7	20
Quarter 4	October - December	16.7	20