

Bridgewater Water Supply

PFAS Results 2023

PFAS6 Results for Wells #2, 4A and 5A 100 Wellfield Drive

Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	18.2	20
Quarter 2	April - June	19.3	20
Quarter 3	July - September		20
Quarter 4	October - December		20

PFAS6 Results for High Street Wells # 3, 6, 8 & 9 1420 High Street

Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	12.4	20
Quarter 2	April - June	9.7	20
Quarter 3	July - September		20
Quarter 4	October - December		20

PFAS6 Results for Plymouth Street Wells # 10A and # 10B 1729 Plymouth Street

Quarterly Compliance Period	Monitoring Period	Quarterly - Results	PFAS6 MCL (ng/L)
		Average (ng/L)	
Quarter 1	January - March	16.7	20
Quarter 2	April - June	15.7	20
Quarter 3	July - September		20
Quarter 4	October - December		20