

2024

100 Well field Dr.

1420 High St.

1729 Plymouth St.

	ID#10061 Wells 2,4a & 5a	ID#10008 Wells 3,6,8 & 9	ID#10046 Wells 10 a & 10 b
Q1	January	17.9	9.31
	February	22	11.6
	March	19.1	9.27
	AVG	19.67	10.06
Q2	April	23.75	12.7
	May	17.80	11.7
	June	18.00	9.41
	AVG	19.85	11.3
Q3	July 1, 2024		21
	7/18/2024 *	17	10.3
	August	21.1	10.9
	September	28.1	17.5
	AVG	22.07	12.90
Q4	October		
	November		
	December		
	AVG		

* an additional sample was collected in the month of July for Wells 10 a and b

Massachusetts Department of Environmental Protection (MassDEP)
 PFAS Quarterly maximum contaminant level (MCL) is
 20 nanograms per liter (ng/l)