

2024

100 Well field Dr.

1420 High St.

1729 Plymouth St.

	ID#10061 Wells 2,4a & 5a	ID#10081 Wells 3,6,8 & 9	ID#10046 Wells 10 a & 10 b
Q1	January	17.9	9.31
	February	22	11.6
	March	19.1	9.27
	AVG	19.67	10.06
Q2	April	23.75	12.7
	May	17.80	11.7
	June	18.00	9.41
	AVG	19.85	11.3
Q3	July 1, 2024		21
	7/18/2024 *	17	10.3
	August	21.1	10.9
	September	28.1	17.5
	AVG	22.07	12.90
Q4	October	17.6	9.8
	November	21	12.1
	December	24.8	na
	AVG	21.13	10.95

Massachusetts Department of Environmental Protection (MassDEP)

PFAS Quarterly maximum contaminant level (MCL) is
nanograms per liter (ng/l)

20